



**IKATES, s.r.o.**

Tolstého 186, 415 03 Teplice, Czech Republic  
Company ID : 25032836

CERTIFICATION BODY

ISSUES

# CERTIFICATE OF CONFORMITY

No.: CN-38B/2015

**TO THE APPLICANT :** JASIEK POLSKA Sp. z o.o., Wilkowo 75  
66-200 Świebodzin, Poland

**FOR THE PRODUCT** Insulating triple glass units  
(identification) :

**PRODUCER :** JASIEK POLSKA Sp. z o.o., Wilkowo 75  
66-200 Świebodzin, Poland

**CONCLUSION / CLASSIFICATION :**


Thermal transmittance of the above mentioned insulating glass unit determined according ČSN EN 673 (2011):

Insulating glass unit structure	U (W.m <sup>-2</sup> .K <sup>-1</sup> )
1. Climaguard Premium 4 mm (#2) - 10 mm argon - float glass 4 mm - 10 mm argon - Climaguard Premium 4 mm (#3)	0,8
2. Climaguard Premium 4 mm (#2) - 12 mm argon - float glass 4 mm - 12 mm argon - Climaguard Premium 4 mm (#3)	0,7
3. Climaguard Premium 4 mm (#2) - 14 mm argon - float glass 4 mm - 14 mm argon - Climaguard Premium 4 mm (#3)	0,6
4. Climaguard Premium 4 mm (#2) - 16 mm argon - float glass 4 mm - 16 mm argon - Climaguard Premium 4 mm (#3)	0,6
5. Climaguard Premium 4 mm (#2) - 18 mm argon - float glass 4 mm - 18 mm argon - Climaguard Premium 4 mm (#3)	0,5
6. laminated glass 33.1 Climaguard Premium (#2) - 12 mm argon - float glass 4 mm - 12 mm argon - Climaguard Premium 4 mm (#5)	0,7
7. laminated glass 33.2 - 12 mm argon - Climaguard Premium 4 mm (#3) - 12 mm argon - Climaguard Premium 4 mm (#5)	0,7
8. laminated glass 33.4 - 12 mm argon - Climaguard Premium 4 mm (#3) - 12 mm argon - Climaguard Premium 4 mm (#5)	0,7

Certificate has been issued on the basis of the Test reports No. 253/2012 of the testing laboratory No.1139 IKATES, s.r.o. Teplice, accredited by ČIA.

Rules for the use of certificate are attached on the second side of this certificate.

Date of issue : 2015-11-05  
Validity till : 2018-11-05



.....  
Lubomír Hnilička  
Manager of the Certification Body