



# IKATES, s.r.o.

Tolstého 186, 415 03 Teplice, Czech Republic

Company ID : 25032836

CERTIFICATION BODY

ISSUES

## CERTIFICATE OF CONFORMITY

No.: CN-18B/2012

TO THE APPLICANT : JASIEK POLSKA Sp. z o.o., Wilkowo 75  
66-200 Świebodzin, Poland

FOR THE PRODUCT (identification) : Insulating triple glass units

PRODUCER : JASIEK POLSKA Sp. z o.o., Wilkowo 75  
66-200 Świebodzin, Poland

CONCLUSION / CLASSIFICATION :

Thermal transmittance of the above mentioned insulating glass unit determined according ČSN EN 673 :

Insulating glass unit structure	U (W.m <sup>-2</sup> .K <sup>-1</sup> )
1. Climaguard Premium 4 mm (#2) - 10 mm argon - float glass 4 mm - 10 mm argon - Climaguard Premium 4 mm (#3)	0,8
2. Climaguard Premium 4 mm (#2) - 12 mm argon - float glass 4 mm - 12 mm argon - Climaguard Premium 4 mm (#3)	0,7
3. Climaguard Premium 4 mm (#2) - 14 mm argon - float glass 4 mm - 14 mm argon - Climaguard Premium 4 mm (#3)	0,6
4. Climaguard Premium 4 mm (#2) - 16 mm argon - float glass 4 mm - 16 mm argon - Climaguard Premium 4 mm (#3)	0,6
5. Climaguard Premium 4 mm (#2) - 18 mm argon - float glass 4 mm - 18 mm argon - Climaguard Premium 4 mm (#3)	0,5
6. laminated glass 33.1 Climaguard Premium (#2) - 12 mm argon - float glass 4 mm - 12 mm argon - Climaguard Premium 4 mm (#5)	0,7
7. laminated glass 33.2 - 12 mm argon - Climaguard Premium 4 mm (#3) - 12 mm argon - Climaguard Premium 4 mm (#5)	0,7
8. laminated glass 33.4 - 12 mm argon - Climaguard Premium 4 mm (#3) - 12 mm argon - Climaguard Premium 4 mm (#5)	0,7

Certificate has been issued on the basis of the Test reports No. 253/2012 of the accredited testing laboratory No.1139 IKATES, s.r.o., Teplice.

Rules for the use of certificate are adduced on the second side of this certificate.

Date of issue : 2012-11-05  
Validity till : 2015-11-05



  
Lubomír Hnilička  
Manager of the Certification Body