



IKATES, s.r.o.

Tolstého 186, 415 03 Teplice, Czech Republic

Company ID : 25032836

CERTIFICATION BODY

ISSUES

CERTIFICATE OF CONFORMITY

No.: CN-18A/2012

TO THE APPLICANT : JASIEK POLSKA Sp. z o.o., Wilkowo 75
66-200 Świebodzin, Poland

FOR THE PRODUCT Insulating double glass units
(identification) :

PRODUCER : JASIEK POLSKA Sp. z o.o., Wilkowo 75
66-200 Świebodzin, Poland

CONCLUSION / CLASSIFICATION :

Thermal transmittance of the above mentioned insulating glass unit determined according ČSN EN 673 :

insulating glass unit structure	U (W.m ⁻² .K ⁻¹)
1. Climaguard Premium 4 mm (#2) - 12 mm argon - float glass 4 mm	1,3
2. Climaguard Premium 4 mm (#2) - 14 mm argon - float glass 4 mm	1,2
3. Climaguard Premium 4 mm (#2) - 16 mm argon - float glass 4 mm	1,1
4. float glass 4 mm - 12 mm argon - Climaguard Premium 4 mm (#3)	1,3
5. float glass 4 mm - 14 mm argon - Climaguard Premium 4 mm (#3)	1,2
6. float glass 4 mm - 16 mm argon - Climaguard Premium 4 mm (#3)	1,1
7. Climaguard Premium 4 mm (#2) - 12 mm argon - Climaguard Premium 4 mm (#3)	1,2
8. Climaguard Premium 4 mm (#2) - 16 mm argon - Climaguard Premium 4 mm (#3)	1,0
9. float glass 6 mm - 14 mm argon - Climaguard Premium 4 mm (#3)	1,1
10. float glass 6 mm - 16 mm argon - Climaguard Premium 4 mm (#3)	1,1
11. float glass 8 mm - 12 mm argon - Climaguard Premium 4 mm (#3)	1,3
12. float glass 8 mm - 16 mm argon - Climaguard Premium 4 mm (#3)	1,1
13. laminated glass 33.1 - 14 mm argon - Climaguard Premium 4 mm (#3)	1,1
14. laminated glass 44.2 - 12 mm argon - Climaguard Premium 4 mm (#3)	1,3
15. float glass 4 mm - 16 mm argon - Climaguard 1,0 4 mm (#3)	1,0
16. laminated glass 33.1 - 16 mm argon - laminated glass 33.1 Climaguard Premium (#3)	1,1
17. laminated glass 33.1 - 16 mm argon - Climaguard Premium 6 mm (#3)	1,1

Certificate has been issued on the basis of the Test reports No.253/2012 of the accredited testing laboratory No.1139 IKATES, s.r.o., Teplice.

Rules for the use of certificate are adduced on the second side of this certificate.

Date of issue : 2012-11-05
Validity till : 2015-11-05



.....
Lubomír Hnilička
Manager of the Certification Body